

Average Elevation of Pervious Areas= 9.50 feet NGVD

Step 4:

Determine the distance between the average high ground water elevation and the average elevation of the pervious areas. For design purposes, the average high ground water elevation for most of Golden Beach is 2 feet NGVD (Additionally, please check with your geotechnical engineer and/or geotechnical report.)

Distance= 7 feet

Step 5:

Determine an S_1 value from the table below:

Distance between ground water table and average elevation of pervious areas,	S_1
1 foot	0.45 inches
2 feet	1.88 inches
3 feet	4.95 inches
4 feet	8.18 inches
>4 feet	8.18 inches

If necessary, compute a value of S_1 by interpolation.

S_1 = 8.18 inches

Step 6:

Determine S as:

$$S = \frac{AP}{A}$$

$$*S_1$$

S is computed in inches $S =$ 3.00 inches

Step 7:

Determine runoff depth (R) as:

$$R = \frac{(P - 0.2 * S)^2}{(P + 0.8 * S)}$$

Where P= 7.00 inches of rainfall produced during a 10- year/ one-day storm. Then:

$$R = \frac{(7.00 - 0.2 * S)^2}{(P + 0.8 * S)}$$

$$(7.00+0.8*S)$$

R is computed in inches R= 4.36 inches

Step 8:

Determine runoff depth (R) as:

$$V = \frac{A * R}{12}$$

V is computed in cubic feet. V is the volume of runoff generated during a 10 year- year/ one day storm within the property or sub-basin of the property.

$$V = \underline{4360} \text{ cubic feet}$$

Step 9:

Compute "retention volume provided" (VP) as the retention volume capacity, in cubic feet, of swales, retention areas, and drains within the property or sub-basin within the property.

- Attach calculation showing how the volume was calculated.
- Calculations must be consistent with existing and proposed elevations shown on design plans.

$$VP = \underline{4,395.11} \text{ cubic feet}$$

Step 10:

Compute values of retention volume provided (VP in Step 9) with retention volumes needed (V in Step 8). Retention volume provided (VP) must be larger than retention volume needed (V). (VP= 4395.11 cubic feet) > (V= 4360 cubic feet)

NOTE: These volumes calculations are needed to satisfy the Town of Golden Beach Comprehensive Plan Level of Service (LOS) and Code requirements.

DEFINITIONS			
P:	Rainfall depth in inches.	A:	Total area of property in square feet.
S:	Soil storage capacity in inches.	AP:	Total pervious areas within property in square feet.
R:	Runoff depth in inches.	V:	Volume of runoff in cubic feet.
AI:	Total area of roof, pavement patios, pool decks, walkways and any other hardscape areas within the property in square feet (ie., total impervious area).		

Note:* means multiply.

PABLO J UMANSKY TRS
UMANSKY 2015 FAMILY TRUST
57 E WILLOW TREE RD
SPRING VALLEY, NY 10977 USA

NORMAN B GAYLIS TRS
NORMAN B GAYLIS DECL OF TRUST
179 OCEAN BLVD
GOLDEN BEACH, FL 33160

SCOTT SCHLESINGER
201 OCEAN BLVD
GOLDEN BEACH, FL 33160-2209

BRENDA MCHUGH
195 OCEAN BLVD
GOLDEN BEACH, FL 33160

GOLD BEACH 2020 LLC
C/O MOISES GRAYSON ESQ
25 SE SECOND AVE 730
MIAMI, FL 33131

176 OCEAN GB LLC
1212 SE 3 AVE
FORT LAUDERDALE, FL 33316

KEVIN P MALONEY
191 OCEAN BLVD
GOLDEN BEACH, FL 33160

JEAN-PIERRE LEVY
175 OCEAN BLVD
GOLDEN BEACH, FL 33160-2208

PIETRO OPPEDISANO
31-07 FARRINGTON ST
FLUSHING, NY 11354

SCOTT P SCHLESINGER
201 OCEAN BLVD
GOLDEN BEACH, FL 33160 USA

ARYEH RUBIN & W RAQUEL
165 OCEAN BLVD
GOLDEN BEACH, FL 33160-2208

AVRAM SABAN
ESTY DANINO SABAN
162 OCEAN BLVD
GOLDEN BEACH, FL 33160

IGOR V SIVOKOZOV TRS
IGOR V SIVOKOZOV TRUST
205 OCEAN BLVD
GOLDEN BEACH, FL 33160

HEDY WHITEBOOK & H
DANIEL S WHITEBOOK
155 OCEAN BLVD
AVENTURA, FL 33160-2208

ORIAN AZULAY
DIKLA E AZULAY
152 OCEAN BLVD
GOLDEN BEACH, FL 33160

CAMILLE KRESTOW
VICTOR P KRESTOW
215 OCEAN BLVD
GOLDEN BEACH, FL 33160

145 OCEAN BLVD LLC
16901 COLLINS AVE UNIT 805
SUNNY ISLES BEACH, FL 33160 USA

PETER G MANNERS TRS
MANNERS HEADLEY FMY LIFE CARE TR
MICHELLE C HEADLEY TRS
198 OCEAN BLVD
GOLDEN BEACH, FL 33160

CHAY AMAR (LESSOR)
NEHAMA AMAR (LESSOR)
ME-YAD JEWISH OUTREACH PROGRAM-
CHABAD OF GOLDEN BEACH INC LEASSE
200 OCEAN BLVD
GOLDEN BEACH, FL 33160-2210

RYAN ALEXANDER JUNEE
ALINA KOCHKAROVA
210 OCEAN BLVD
GOLDEN BEACH, FL 33160

RUBEN SALAMA
ROCHEL LEA WILDSTEIN SALAMA
220 OCEAN BLVD
GOLDEN BEACH, FL 33160



TOWN OF GOLDEN BEACH
1 Golden Beach Drive
Golden Beach, FL 33160

Summary Minutes
BUILDING REGULATION ADVISORY BOARD
August 10, 2021 at 6pm

Zoom Meeting ID: 892 9110 8015 Passcode: 752288 For Dial in only call:
929-205-6099

- A. CALL MEETING TO ORDER: 6:04**
- B. BOARD ATTENDANCE:** Jerome Hollo, Isaac Murciano and Alan Macken
Absent: Judy Mimoun, Zvi Shiff, Eric Cohen and Stephanie Halfen
- C. STAFF ATTENDANCE:** Linda Epperson- Building & Zoning Director and Michael Miller, Michael Miller Planning.
- D. APPROVAL OF MINUTES:** June 8, 2021

A motion to approve the minutes by Isaac Murciano, Seconded by Alan Macken
All were in favor – no one opposed
Motion passed 3 – 0

E. REQUEST FOR ADDITIONS, DEFERRALS, DELETIONS & WITHDRAWALS

1. 422 GB LLC
18200 Ne 19 Ave, Ste 101
North Miami Beach, FL 33162

Property Address: 422 Golden Beach Drive, Golden Beach, FL 33160-0000
Folio No: 19-1235-005-0510
Legal Description: Lot 45 & N1/2 of Lot 46 BLK F GB Sec E PB 8-122

Seawall Reinforcement and new dock.

2. 416 Golden Beach LLC
17600 Collins Ave
Sunny Isles Beach, FL 33160

Property Address: 416 Golden Beach Drive, Golden Beach, FL 33160-0000
Folio No: 19-1235-005-0520
Legal Description: Lot 47 & S1/2 of Lot 46 & Lot 48 Blk F

Construction of a new single-family residence and landscape design approval.

3. Evgeny Melashchenko
194 South Island Drive
Sunny Isles Beach, FL 33160

Property Address: 194 South Island Drive, Golden Beach, FL 33160
Folio No: 19-1235-004-0650
Legal Description: Lot 26 & S35FT of Lot 27 Blk J GB Sec D PB 10-10

Construction of a new two story single-family residence, gazebo, and landscape design approval.

4. GB 620 LLC
19495 Biscayne Blvd 608
Aventura, FL 33180

Property Address: 620 Ocean Blvd., Golden Beach, FL 33160-0000
Folio No: 19-1235-001-0060
Legal Description: Lot 6 & 7 Blk 1 GB Sec A PB 9-52

Construction of a new single-family residence and landscape design approval.

5. Germany House LLC
136 Ocean Blvd
Golden Beach, FL 33160

Property Address: 136 Ocean Blvd., Golden Beach, FL 33160-0000
Folio No: 19-1235-003-0610
Legal Description: Lot 12 & 13, Blk 6 GB Sec C PB 9-52

Construction of a new single-family residence, terrace, and landscape design approval.

6. Pablo J. Umansky Trs. - Umansky Family Trust
57 E Willow Tree Rd
Spring Valley, NY 10977

Property Address: 185 Ocean Blvd., Golden Beach, FL 33160-0000
Folio No: 19-1235-003-0150
Legal Description: Lot 18 BLK A GB Sec C PB 9-52

Demolition of an existing structure and construction of a new three story single-family residence.

A motion to approve deferring items 1 – 6 to the next Building Advisory Board meeting
by Isaac Murciano, Seconded by Alan Macken
All were in favor – no one opposed
Motion passed 3 – 0

F. VARIANCE REQUEST(S):

7. Pablo J. Umansky Trs. - Umansky Family Trust
57 E Willow Tree Rd
Spring Valley, NY 10977

Property Address: 185 Ocean Blvd., Golden Beach, FL 33160-0000
Folio No: 19-1235-003-0150
Legal Description: Lot 18 BLK A GB Sec C PB 9-52

Demolition of an existing structure and construction of a new three story single-family residence.

Variance requests for a proposed new single-family residence located in Zone 1.

Michael Miller - Miller Planning summarized his reports into the record.
Shane Ames – Architect for project spoke on behalf of the applicant

Relief from Town Code Sec. 66-102. - Minimum lot and swale elevations; grade.

(a) The finished grade of any lot shall not exceed an elevation of 24 inches above the crown of the road adjacent to the lot and in no event shall exceed an elevation of six feet N.G.V.D. except for lots abutting Ocean Boulevard where the minimum elevation shall be 12 inches above the crown of the road, and the maximum elevation shall not exceed an elevation of 11 feet N.G.V.D. Exterior slabs and walkways shall not exceed an elevation of 36 inches above the crown of the road adjacent to the lot.

Request is to allow portions of the rear yard elevations around the pool area to be between 11.0' NGVD and 12.0' NGVD.

In accordance with Town Code Section 66-41, "authorized, general procedure", pertaining to variances, the board considered all evidence and testimony presented by the applicant, the public and the Town and made a finding that the applicant has complied with the seven criteria.

Motion to recommend approval by Alan Macken, Seconded by Isaac Murciano
On roll call: Isaac Murciano- Aye, Alan Macken – Aye and Jerome Hollo-Aye
Motion passed 3 – 0

Relief from Town Code Sec. 66-69.1 - Zone One (Oceanfront properties); (h) (1) (c)

(h) Side yard Setbacks. - (1) Main Residence.

c. All residences designed as two-story structures shall be required to increase the side Setbacks along two-thirds of the length of the second story by one foot for each one foot (1:1) of building height above the first 18 feet.

Request is to allow the applicant not to increase the side setbacks in the second story by one foot for each one foot (1:1) of building height above the first 18 feet, along two-thirds of the length of the building.

In accordance with Town Code Section 66-41, "authorized, general procedure", pertaining to variances, the board considered all evidence and testimony presented by the applicant, the public and the Town and made a finding that the applicant has complied with the seven criteria.

Motion to recommend approval by Alan Macken, Seconded by Isaac Murciano
On roll call: Isaac Murciano- No, Alan Macken – Yes and Jerome Hollo-No
Motion failed 2 – 1

G. OLD BUSINESS:

8. Tariq Smith & Audra Schnepf Charif
530 North Parkway
Golden Beach, FL 33160

Property Address: 530 North Parkway, Golden Beach, FL 33160-0000
Folio No: 19-1235-006-0710
Legal Description: Lot 17 BLK F GB Sec F PB 10-11

Michael Miller – Michael Miller Planning summarized his report into the record.
Henry Albello – Trident on behalf of the applicant

Seawall Reinforcement and new timber dock.

A motion to approve by Isaac Murciano, Seconded by Alan Macken
Conditioned on a six-inch drainage area at the seawall. The condition was accepted and
On roll call: Isaac Murciano – Aye, Alan Macken-Aye and Jerome Hollo-Aye
Motion passed 3 – 0

- 9. X Group LLC
2980 NE 207th St, Ste 804
Miami, FL 33180-1466

Property Address: 650 Golden Beach Drive, Golden Beach, FL 33160-0000
Folio No: 19-1235-006-0440
Legal Description: Lot 9 & 10 BLK E GB Sec C PB 10-11

Michael Miller – Michael Miller Planning summarized his report into the record.
Henry Albello – Trident on behalf of the applicant

Seawall Reinforcement and new timber dock.

A motion to approve by Alan Macken, Seconded by Isaac Murciano
Conditioned on the depth of the dock from property line to be at what is permitted by
Town's code and to lower the dock decking over seawall cap to a not to exceed 4.425'
NAVD 88 instead of the 4.450' NAVD 88 shown on the plans.
On roll call: Isaac Murciano – Aye, Alan Macken-Aye and Jerome Hollo-Aye
Motion passed 3 – 0

H. NEW BUSINESS:

I. PRELIMINARY DESIGN REVIEWS - ITEMS FOR DISCUSSION AND POSSIBLE APPROVAL

I. ADJOURNMENT 7:00pm

PURSUANT TO FLA. STATUTE 286.0105, THE TOWN HEREBY ADVISES THE PUBLIC THAT: IF A PERSON DECIDES TO APPEAL ANY DECISION MADE BY THIS BOARD WITH RESPECT TO ANY MATTER CONSIDERED AT ITS MEETING OR HEARING, HE WILL NEED A RECORD OF THE PROCEEDINGS, AND FOR THAT SUCH PURPOSE, AFFECTED PERSONS MAY NEED TO ENSURE THAT A VERBATIM RECORD OF THE PROCEEDINGS IS MADE, WHICH RECORD INCLUDES THE TESTIMONY AND EVIDENCE UPON WHICH THE APPEAL IS TO BE BASED. THIS NOTICE DOES NOT CONSTITUTE CONSENT BY THE TOWN FOR THE INTRODUCTION OR ADMISSION OF OTHER INADMISSIBLE OR IRRELEVANT EVIDENCE, NOR DOES I

PROJECT FOR THE NEW RESIDENCE OF DR. PABLO UMANSKY



DR AB
SPECIM DONE
8/10/2021
DESIGN
NOT APPROVED
VARIANCE
APPLICATION
FOR 2ND FLOOR
SPECIM EXEMPT
ONLY

INDEX OF DRAWINGS		Town of Building Regulation Department Hos
SHEET NUMBER	SHEET NAME	
A-00	COVER SHEET	
A-01	3D VIEWS	
00	SURVEY	
G-01	STORMWATER POLLUTION PREVENTION PLAN	
C-02	CIVIL PLAN	
G-03	SWALE SECTIONS & DETAILS	
TD-01	TREE DISPOSITION PLAN	
L-01	LANDSCAPE PLAN	
L-02	HARDSCAPE PLAN	
A-02.1	SITE PLAN	
A-02.2	SITE PLAN	
A-02.3	FLOOR AREA CALCULATIONS	
A-03	BASEMENT NOTATION PLAN	
A-04	BASEMENT DIMENSION FLOOR PLAN	
A-05	1ST FLOOR NOTATION PLAN	
A-06	1ST FLOOR DIMENSION PLAN	
A-07	2ND FLOOR NOTATION PLAN	
A-08	2ND FLOOR DIMENSION PLAN	
A-09	ARCHITECTURAL ROOF PLAN	
A-10	BUILDING ELEVATIONS	
A-11	BUILDING ELEVATION	
A-12	BUILDING ELEVATION	
A-13	BUILDING ELEVATION	
A-14	BUILDING SECTION	
A-15	BUILDING SECTION	
A-16	BUILDING SECTION	
A-17	BUILDING SECTION	
A-18	BUILDING SECTION	
A-19	BUILDING SECTION & TYPICAL WALL SECTION	
000	MATERIAL SAMPLE PRESENTATION	

Town of Golden Beach
Building Regulatory Advisory Board
Hearing Date

AUG 10 2021


APPROVED
DISAPPROVED
VARIANCE REQ

BRAB REVIEW SET (REV #1)

UMANSKY, DR. PABLO
185 OCEAN BLVD
GOLDEN BEACH
FLORIDA 33160

[illegible]

SYMBOLS LEGEND



MATERIALS LIST

	STRUCTURAL CONC. COLUMN OR SHEER WALL
	CONCRETE BLOCK
	STRUCTURAL BEARING WALL
	1 HR FIRE-RATED PARTITION (AS PER S.F.B.C. 37-B #79)
	GYPSUM BOARD
	CONCRETE, MORTAR, OR GROUT
	PLYWOOD
	FINISH WOOD

COVER SHEET

DRAWN
A.T.
CHECKED
S.A.
DATE
07/15/2021
SCALE
1/4" = 1'-0"
JOB NO.
20 4992
SHEET

A-00

OF # SHEETS

Unit# : AA0002307 ARCH R# : AR00012001
ADDRESS : HISTORIC DELIDA PARK, PROFESSIONAL DISTRICT, 203 DIXIE BOULEVARD, DELRAY BEACH, FLORIDA, 33444 PHONE : (561)274 6444 FAX : (561)2746446;

Shane Ames - Architect



Ames
INTERNATIONAL
ARCHITECTURE



OWNERSHIP OF 2D-2 AND 3D ARCHITECTURE: OWNERSHIP OF PLANS AND SPECIFICATIONS: PLANS, DESIGNS, DRAWINGS AND SPECIFICATIONS ARE THE INSTRUMENTS OF SERVICE AND ARE OWNED BY AMES INTERNATIONAL ARCHITECTURE AND THEY REMAIN THE SOLE AND EXCLUSIVE PROPERTY OF AMES INTERNATIONAL ARCHITECTURE AND MAY BE USED BY AMES INTERNATIONAL ARCHITECTURE FOR ANY PURPOSE WHATSOEVER. THE PLANS, DESIGNS, DRAWINGS AND SPECIFICATIONS ARE LOANED TO THE CLIENT FOR THE PURPOSE OF BUILDING THE PROJECT ONLY. THE PLANS, DESIGNS, DRAWINGS AND SPECIFICATIONS SHALL NOT BE REPRODUCED BY THE CLIENT AND/OR ITS AGENTS IN WHOLE OR IN PART IN ANY MANNER. THESE DOCUMENTS SHALL NOT BE SUBMITTED BY THE CLIENT AND/OR ITS AGENTS TO ANY THIRD PARTY FOR EXAMINATION AND/OR FOR THE PURPOSE AND INTENT OF COPYING AND/OR BUILDING THIS PARTICULAR PROJECT WITHOUT THE EXPRESS WRITTEN CONSENT OF AMES INTERNATIONAL ARCHITECTURE. THESE DOCUMENTS SHALL ONLY BE USED BY THE CLIENT AND/OR AGENTS FOR THE BUILDING OF THIS PROJECT. COPYRIGHT INFRINGEMENTS: AMES INTERNATIONAL ARCHITECTURE WILL PROSECUTE ALL COPYRIGHT INFRINGEMENTS INVOLVING AMES INTERNATIONAL ARCHITECTURE PLANS, DESIGNS, DRAWINGS AND SPECIFICATIONS.

3D VIEWS

DRAWN	
A.T.	
CHECKED	
S. A.	
DATE	07/15/2021
SCALE	
JOB NO.	20 4592
SHEET	
A-01	
CF	#
SHEETS	



Shane Ames - Architect

[illegible]

BRAB REVIEW SET (REV #1)

UMANSKY, DR. PABLO
185 OCEAN BLVD
GOLDEN BEACH
FLORIDA 33160

(REV #1)
Town of Golden Beach
Building Regulatory Advisory Board
Hearing Date

AUG 10 2021

APPROVED _____
DISAPPROVED _____
VARIANCE REQ: _____


LOT 18, BLOCK "A", SECTION "C" OF GOLDEN BEACH, ACCORDING TO THE PLAT THEREOF, AS RECORDED IN THE PLAT BOOK 9, PAGE 52, OF THE PUBLIC RECORDS OF MIAMI-DADE COUNTY, FLORIDA.

1. SURVEY DATA IS BASED ON INFORMATION PROVIDED BY BASELINE ENGINEERING & LAND SURVEYING, INC.
2. THE ELEVATIONS ARE PROVIDED IN THE NATIONAL GEODETIC VERTICAL DATUM (NGVD 1929)
3. FLOOD ZONE AE, BASE FLOOD EL. = 7', MAP DATE 09/11/09; MAP NUMBER 12086 0153L
4. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL GIVE TIMELY NOTIFICATION TO ALL UTILITY COMPANIES WITH FACILITIES IN THE AREA.
5. THE LOCATION OF EXISTING FACILITIES WERE PLOTTED FROM AVAILABLE RECORDS. THE CONTRACTOR SHALL FIELD LOCATE ALL EXISTING UTILITIES PRIOR TO CONSTRUCTION.
6. THE CONTRACTOR SHALL TAKE ALL NECESSARY PRECAUTIONS TO SAFEGUARD ALL EXISTING STRUCTURES, UTILITIES, AND SURVEY MAKERS.
7. ALL SIDEWALKS AND PATIOS SHALL BE SLOPED AWAY FROM HOUSE.
8. MAXIMUM GRASS SLOPES SHALL NOT EXCEED 4:1.
9. CONTRACTOR SHALL COORDINATE GRADING PLAN WITH LANDSCAPE PLAN.

1. PROVIDE FILTER FABRIC OR OTHER METHOD OF SEDIMENT PROTECTION FOR ANY EXISTING CATCH BASIN/INLET WITHIN 100 FEET OF THE PROPERTY. ANY SEDIMENT THAT IS TRACKED ONTO THE ROAD MUST BE SWEEP UP IMMEDIATELY. SEDIMENT SHALL NOT BE REMOVED BY WASHING/FLUSHING WITH WATER AT THE RIGHT OF WAY.
2. AT ALL TIMES DURING CONSTRUCTION, ALL STORMWATER MUST REMAIN ONSITE. NO DISCHARGE IS ALLOWED INTO THE PUBLIC RIGHT OF WAY.
3. CONTRACTOR SHALL USE BEST MANAGEMENT PRACTICES IN ORDER TO PROVIDED STORMWATER, EROSION AND SEDIMENTATION CONTROL FOR THE SITE AND ESPECIALLY BEYOND THE LIMITS OF EXCAVATION.
4. A 5" CHANNEL DRAIN SHALL BE INSTALLED ACROSS THE WIDTH OF THE POOL DECK AND SHALL BE BY FERROCO OR EQUAL.
5. THE CHANNEL DRAIN SHALL DISCHARGE THROUGH A 6 INCH POLY PIPE INTO A DRY WELL/ EXFILTRATION TRENCH SYSTEM.
6. INSTALL DRAINAGE SYSTEMS AND SWALES AS PER DETAILS.
7. ADJUST EXISTING UTILITIES AS MAYBE REQUIRED TO MEET THE NEW GRADES.

BUILDING FOOTPRINT	3,108 SQ FT	25.90 %
POOL/DECK/GAZEBO	2,540 SQ FT	36.72 %
MOTOR COURT/GARBAGE AREA	1,946 SQ FT	63.28 %
TOTAL AREA	12,000 SQ FT	100.00 %
TOTAL PERVIOUS AREA	4,406 SQ FT	36.72 %
TOTAL IMPERVIOUS AREA	7,594 SQ FT	63.28 %

* 10.78	EXISTING ELEVATION (NGVD)
	EX. WATER METER
COO	PROP. CLEAN OUT
	PROPERTY LINE
	PROP. SITE GRADE (NGVD)
	PROP. SWALE
	PROP. CATCH BASIN



**Town of Golden Beach
Building Regulatory Advisory Board
Hearing Date**

AUG 10 2021

APPROVED
DISAPPROVED
VARIANCE REQ:

UMANSKY RESIDENCE
185 S OCEAN BOULEVARD
GOLDEN BEACH, FL 33160

REVISIONS		
NO.	DATE	DESCRIPTION

GEA PROJECT NO. : 21061
DATE : 05-28-2021
SCALE : AS SHOWN
DESIGNED BY : R.B.J.
DRAWN BY : L.B.
CHECKED BY : R.B.J.
APPROVED BY : R.B.J.

SHEET TITLE

CIVIL PLAN

C2 OF **3**

SEAL

DATE: _____
REGINA BOBO-JACKSON, P.E.
FL P.E. NO.: 38550

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT



**GATOR ENGINEERING
ASSOCIATES, INC.**
11300 TEMPLE STREET
COOPER CITY, FL 33330
TEL: (904) 434-5906 FAX: (904) 434-5604
CERTIFICATE OF AUTHORIZATION NUMBER 30290

STORAGE CALCULATIONS:

SEE THE DRAINAGE COMPUTATIONS FOR THE VOLUME OF RUNOFF TO BE CONTAINED ON SITE. $V = 4,360$ CF

SWALE A = $(53.67 \text{ SF} \times 0.5') + (29.58' \times 2\frac{1}{2}' \times 0.50') = 41.63$ CF
SWALE B = $(230' \times 4.33\frac{1}{2}' \times 0.50') = 248.97$ CF
SWALE C1 = $(178.04' \times 4.33\frac{1}{2}' \times 0.5') = 179.11$ CF
SWALE C2 = $(33.12' \times 4.33\frac{1}{2}' \times 0.5') = 35.85$ CF

TOTAL SWALES = 505.56 CF

EXFILTRATION TRENCH:
BALANCE OF VOLUME REQUIRED: $3854.44 \text{ CF} / (43,560 \text{ AC/FT} \times 12 \text{ IN/FT}) = 1/06\text{-IN}$




COMPUTATION OF TRENCH VOLUME

$L = V / (K(H_2W + 2H_2DU - DU^2 + 2H_2DS) + (1.39 \times 10^{-4})(W DU))$
(WHEN $DS < DU$)
L = LENGTH OF TRENCH REQUIRED (FEET)
V = VOLUME TO BE EXFILTRATED (AC-IN)
W = TRENCH WIDTH (FEET)
K = HYDRAULIC CONDUCTIVITY (CFS/FT²- FT. HEAD)
H₂ = DEPTH TO WATER TABLE (FEET)
DU = NON-SATURATED TRENCH DEPTH (FEET)
DS = SATURATED TRENCH DEPTH (FEET)
V = 1.06 AC-IN
W = 10.00 FT
K = 2.00×10^{-4} (ASSUMED)
H₂ = 7.50 FT
DU = 6.50 FT
DS = 0.00 FT

$L = 1.06 / (2.00 \times 10^{-4} ((7.50 \times 10.00) + 2(7.50 \times 6.50) + (6.50 \times 6.50) + 2(7.50 \times 0.00)) + 1.39 \times 10^{-4} (10.00 \times 6.50)) =$





$L = 30.21 \text{ LF}$ 30.54 LF USED (3,889.55 CF)

TOTAL VOLUME PROVIDED: = 4,395.11 CF > 4,360 CF (REQUIRED)



- NOTES:
1. PLASTIC FILTER FABRIC PER F.D.O.T. STD. INDEX # 285 SHALL BE USED AT EACH SIDE AND ON TOP, AND AT EACH END OF FRENCH DRAIN TRENCH.
 2. THE DEPTH OF THE EXFILTRATION TRENCH SHALL BE 6.50 FEET.
 3. AFTER THE BALLAST ROCK HAS BEEN PLACED TO THE PROPER ELEVATION IT SHALL BE CAREFULLY VIBRATED OR COMPACTED IN ORDER TO ALLOW FOR INITIAL SETTLEMENT THAT MAY OCCUR. IF IT DOES TAKE PLACE, ADDITIONAL BALLAST ROCK WILL BE ADDED TO RESTORE THE BALLAST ROCK TO THE PROPER ELEVATION SO THAT THE EXFILTRATION TRENCH CAN BE COMPLETED IN ACCORDANCE WITH THE DETAIL.

EXFILTRATION TRENCH DETAIL
N.T.S.



Town of Golden Beach
Building Regulatory Advisory Board
Hearing Data

AUG 10 2021

APPROVED
DISAPPROVED
VARIANCE REQ.



DATE: 08/10/2021
DRAWN BY: J. JACKSON, P.E.
FL P.E. NO.: 38550

UMANSKY RESIDENCE
185 S OCEAN BOULEVARD
GOLDEN BEACH, FL 33160

REVISIONS	DATE	DESCRIPTION
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		

GEA PROJECT NO.: 21061
DATE: 05-28-2021
SCALE: AS SHOWN
DESIGNED BY: R.B.J.
DRAWN BY: L.B.
CHECKED BY: R.B.J.
APPROVED BY: R.B.J.

SHEET TITLE

SWALE SECTIONS
& DETAILS

C3 OF 3